



Renton Regional Fire Authority

Mobile Food Facility Permit Application

Date Submitted: _____

Name of Mobile Food Facility: _____ Is this a Renewal? Yes No

Owner's Mailing Address: _____ Owner's Phone: _____

City/State/Zip: _____

Contact Person: _____ Phone: _____

Email: _____

Operation of a Mobile Food Facility within the City of Renton requires an annual Fire Code Permit at a cost of \$100.00, as well as a fire inspection.

Application and payment are accepted at the time of inspection by appointment only at Fire Station 14, 1900 Lind Ave SW, Renton. Checks ONLY, payable to Renton Regional Fire Authority. **Call 425-430-7043 for an inspection appointment.**

Please Mark All That Apply

- Type 1 hood installed above commercial cooking appliances
 - Hood inspected and tested in past 6 months (MUST PROVIDE DOCUMENTATION OF CLEANING AND SUPPRESSION SYSTEM INSPECTION)
- 2A:20BC extinguisher (APPLIES TO ALL)
- Type K extinguisher (ONLY APPLIES TO FACILITIES THAT ARE COOKING)
- Maximum 2 LP-Gas containers (100 lbs. each)
 - Secured/upright position
 - If in compartment, vented to exterior
 - If on back, adequate impact protection
- Mobile food facility not located within 10 feet of buildings, tents, canopies, or membrane structures
- Street parking allowed within 5 feet of buildings (ONLY FOR EVENTS LASTING 3 OR FEWER DAYS)
- Extension cords are heavy duty (12-14 gauge wire)
 - Listed for outdoor use
- Fire lanes are clear

If the permit is allowed to expire, the mobile food facility is prohibited from operating within the City of Renton until the permit has been renewed and another fire inspection completed.

**A VALID PERMIT MUST BE IN EFFECT FOR THE MOBILE FOOD FACILITY
WHEN OPERATING WITHIN THE CITY OF RENTON**

APPLICANT SIGNATURE REQUIRED

DATE



Renton Regional Fire Authority

Guidelines for Mobile Food Facilities

The following guidelines are designed to advise mobile food vendors of Fire Code Regulations required within the City of Renton.

Please ensure your mobile food facility meets the requirements listed below:

- A Type I hood shall be installed at or above all commercial cooking appliances and domestic cooking appliances used for commercial purposes that produce grease-laden vapors.
- Commercial kitchen exhaust hoods shall comply with the requirements of the International Mechanical Code. Hoods shall be inspected, tested, and maintained in accordance with NFPA 96. (Every 6 months, with documentation from the company that conducted the inspection and certification indicating the date and status of the inspection.)
- Have an approved 2A:20BC and Type K rated fire extinguisher.
- A maximum of two LP gas containers (100 pounds each) with a total aggregate water capacity of 200 pounds is permitted at one mobile food facility.
- LP gas cylinders shall be secured in an approved manner in an upright position. LP gas cylinders shall not be stored within the facility at any time. If stored within a compartment, the compartment shall have approved venting directly to the exterior and must not allow venting to the interior of the facility at any time.
- If LP gas storage is added to the rear of the facility, an appropriate approved bumper shall be added to the rear of the facility to provide adequate impact protection.
- Mobile food facilities shall not be located within 10 feet of buildings, tents, canopies, or membrane structures or within 10 feet of any other mobile food facility. EXCEPTION: Reduce to 5 feet for events when parked on the street.
- Extension cords must be heavy duty (12 to 14-gauge wire) and listed for outdoor use.
- Fire lanes are not to be blocked or restricted at any time.

Questions regarding these Guidelines should be directed to:

Renton Regional Fire Authority

425-430-7024